
Earth rod connection in the concrete earth inspection pit

Views not to scale

310 × 310 × 170


KALOT GROUP · TECHNICAL ILLUSTRATION · NOT TO SCALE

4. Exothermic welding




Permanent connection of the conductor to the top of the earth rod.

3. A clamp




Copper tape to earth rod; tape horizontal on the earth rod.

2. G clamp



Bare copper conductor to earth rod; brass body and stainless steel bolt.

1. U clamp



Bare copper conductor to earth rod; brass clamp with stainless steel U.

Choose the clamp or weld to suit the conductor type and earth rod diameter; connections inside the pit stay accessible for inspection and measurement.

گروه کالوت
KALOT GROUP
Protect Today For Tomorrow
Since: 1972 تاسیس: ۱۳۵۱
www.kalot.ir · Tel +98 21 2268 8852

This document is not contractual; we may update product design, dimensions, weights and images without prior notice.