
Foundation earthing installation details

Foundation section, foundation tap-off and expansion joint

GALVANIZED STEEL TAPE · GST 303 · 30 × 3 mm · 90 mm² · HOT-DIP 70 µm


KALOT GROUP · TECHNICAL ILLUSTRATION · NOT TO SCALE

Expansion joint




Rigid tape never crosses an expansion joint; both sides are joined by two stainless steel bonding points on the wall or column surface, inside the building or above ground level, with a flexible connector between them; the connector is never buried in soil.

Foundation tap-off



The tap-off runs inside the concrete or wall into the building or above ground level; the galvanised conductor never leaves the foundation concrete straight into soil.

Section A-A: strip foundation



Tape on edge on spacers, beside the lowest reinforcement layer and near the outer edge of the foundation, with at least 5 cm of concrete on all sides.

Figures are illustrative and not to scale.

We keep improving our products; please confirm final dimensions with our experts.

This document is not contractual; we may update product design, dimensions, weights and images without prior notice.

گروه کالوت
KALOT GROUP
Protect Today For Tomorrow
Since: 1972 تاسیس: ۱۳۵۱
www.kalot.ir · Tel +98 21 2268 8852